

Texas Department of Transportation

North Tarrant Express Project Reference Information Document

Additional Lighting Guidelines

Additional Lighting Guidelines

- 1) High-mast lighting must not infringe into residential areas adjacent to the Project ROW.
- 2) Minimum inside dimensions for ground boxes shall be 15.25 inches (width) by 28.25 inches (length) by 10 inches (depth).
- 3) Ground box covers shall be 2-inch- (nominal) thick, nonconducting material and labeled “Danger High Voltage Illumination”.
- 4) Riprap aprons shall be provided to ground boxes located in grassy areas.
- 5) Lights shall have an identification tag denoting a contact person or office in case of emergency or for maintenance, and the address and telephone number.